





RoHS

CONTROL MODES

- Position (Microstepping)
- Position/Velocity/Torque (Servo Mode)
- · Indexer, Point-to-Point, PVT
- Camming, Gearing

COMMAND INTERFACE

- CANopen
- · ASCII and discrete I/O
- Stepper commands
- ±10V or PWM velocity/torque (servo mode)
- Master encoder (Gearing/Camming)

COMMUNICATIONS

- CANopen
- RS-232

FEEDBACK

Incremental

· Digital quad A/B encoder

I/O

• Digital: 14 inputs, 6 outputs

Analog: 1 input
DIMENSIONS: MM [IN]
76.3 x 58.2 x 20.5
[3.01 x 2.29 x 0.81]



Model	Ic	Ip	Vdc
R52-090-07	5	7	14~90
R52-090-10	10	10	14~90

DESCRIPTION

Stepnet R52 is a high-performance, DC powered driver for control of stepper motors via CANopen. The R52 operates as an CANopen node using DSP-402 for motion control devices. Supported modes include: Profile Position, Profile Velocity, Interpolated Position Mode (PVT), and Homing.

With encoder feedback a stepper can be operated as a brushless servo motor enabling ± 10 V analog or digital PWM velocity or torque control in addition to CANopen. Direct position control from pulses in CW/CCW, Pulse/Dir, or Quad A/B encoder format works in either microstepping or servo modes.

Twelve high-speed digital inputs with programmable functions are provided, and a lower-speed input for a motor temperature switch.

An SLI (Serial Peripheral Interface) function is supported by another high-speed input and four high-speed digital outputs. If not used for SLI, the input and outputs are programmable for other functions. Two open-drain MOSFET can drive loads powered up to 24 Vdc.

An RS-232 serial port provides a connection to Copley's CME2 software for commissioning, firmware upgrading, and saving configurations to flash memory.

Drive power is transformer-isolated DC from regulated or unregulated power supplies. An AuxHV input is provided for "keep-alive" operation permitting the drive power stage to be completely powered down without losing position information, or communications with the control system.

RUGGEDIZED STANDARDS CONFORMANCE

Ambient Temperature Non-Operating Operating Thermal Shock Operating Relative Humidity Non-Operating Operating Vibration Operating Non-Operating Altitude Operating Shock Crash Safety Operating MIL-STD specifications MIL-STD-IEC specifications IEC-

-50°C to 85°C -40°C to 70°C -40°C to 70°C in 1 minute 95% non-condensing at 60°C 95% non-condensing at 60°C 5 Hz to 500 Hz, up to 3.85 grms -400 m to 12,200 m -400 m to 5,000 m 75 g peak acceleration

40 g peak acceleration 461, 704, 810, 1275, 1399 60068, 60079

Tel: 781-828-8090

Copley Controls, 20 Dan Road, Canton, MA 02021, USA P/N 16-01591 Rev 00

Fax: 781-828-6547 Page 1 of 26



RUGGEDIZED DIGITAL STEPPER DRIVE MODULE



RoHS

GENERAL SPECIFICATIONS

MODEL	R52-090-07	R52-090-10	··· ··
OUTPUT POWER			
Peak Current	7 (5)	10 (7.1)	Adc (Arms-sine), ±5%
Peak time	1	1	Sec
Continuous current	5 (3.5)	10 (7.1)	Adc (Arms-sine) per phase
Maximum Output Voltage			Vout = HV*0.97 - Rout*Iout
NPUT POWER			
HVmin~HVmax	+14 to +90	+14 to +90	Vdc Transformer-isolated
Ipeak	7.7	11	Adc (1 sec) peak
Icont	5.5	11	Adc continuous
Aux HV	+14 to +F	IV Vdc @ 500 mAdc ma	ximum, 2.5 W
WM OUTPUTS			
Туре	Dual H-bridge MOS		ghted PWM, space-vector modulation
PWM ripple frequency		32 kH	Z
ONTROL MODES			
CANopen:			
Microstepping: Profile Positio			
Servo mode: all of the micro			
Analog ±10 Vdc current/velo			
<u> </u>	velocity (servo mode)	, CW/CCW, Step/Directi	on, and quad A/B encoder position commands
OMMAND INPUTS			
Туре		anically isolated from d	rive circuits
Signals	CAN_H, CAN_L		
Data protocol Node-ID Selection		ce Profile DSP-402 , or via digital inputs	
Analog	±10 Vdc	, or via digital imputs	
Digital		uts for CW/CCW. Sten/I	Direction, and quad A/B encoder
Camming	Quad A/B digit		sirection, and quad ty b effected
IGITAL CONTROL			
Digital Control Loops	Current, veloci	ty, position. 100% digit	al loop control
Sampling rate (time)			ty & position loops: 4 kHz (250 µs)
Commutation `		d-oriented control	
Modulation	Center-weighte	ed PWM with space-vect	or modulation
Bandwidths			Ith will vary with tuning & load inductance
HV Compensation		s voltage do not a effect	bandwidth
Minimum load inductance	200 μH line-lin	e	
IGITAL INPUTS			
[IN1~9]			$k\Omega$ pull-up to +5 Vdc, +7 Vdc tolerant
[IN10]			dc max, V_T = 1.5 Vdc min, V_H + = 0.45~1.50 Vdc
[IN10]			$0 k\Omega$ pull-up to +5 Vdc, +7 Vdc tolerant 5~3.35 Vdc, V ₊ - = 1.1~2.15 Vdc, V _u + = 0.65~1.6 Vdc
[IN11]			$5 \sim 3.35 \text{ VdC}$, $V_{T}^{-} = 1.1 \sim 2.15 \text{ VdC}$, $V_{H}^{+} = 0.65 \sim 1.6 \text{ VdC}$ filter, 4.99 k Ω pull-up to +5 Vdc, +24V tolerant
[TIATT]	74LVC2G14 Sc	hmitt trigger, V + = 2.0	$5 \sim 3.35 \text{ Vdc}, V_{\tau}^{-} = 1.1 \sim 2.15 \text{ Vdc}, V_{\mu}^{+} = 0.65 \sim 1.6 \text{ Vdc}$
[IN12~14]	GP inputs, 1.5	us RC filter. 15 kO null-	up to $+5$ Vdc, $+24$ Vdc tolerant
F			dc max, V_T = 1.5 Vdc min, V_H + = 0.45~1.50 Vdc
GITAL OUTPUTS	-	22 . 1	e in the second
[OUT1~2]	Open-drain MO	SFET with 1 kΩ pull-un	with series diode to +5 Vdc
F3		, +30 Vdc max. Function	
[OUT3~6]			als, 74AHCT125 line drivers; +5 Vdc tolerant
NALOG INPUT	·		
Type	±10 Vdc, 12-bi	t resolution, differential	
EDBACK	,		
Incremental:			
Disital Insurantal Francisco		(A (A B (B) (V)	lifferential (V /V Index, signals and manyined)

Quadrature signals, (A, /A, B, /B, X, /X), differential (X, /X Index signals not required) Digital Incremental Encoder

Tel: 781-828-8090

5 MHz maximum line frequency (20 M counts/sec) 26LS32 differential line receiver with 121 Ω terminating resistor between complementary inputs wer +5 Vdc ±2% @ 400 mAdc max, protected against shorts and overtemperature Encoder power

Fax: 781-828-6547 Page 2 of 26







RoHS

RS-232 PORT

Signals RxD, TxD, Gnd for operation as a DTE device

Mode Full-duplex, DTE serial port for drive setup and control, 9,600 to 115,200 Baud

Protocol ASCII or Binary format

MOTOR CONNECTIONS

Phases A, /A, B, /B PWM outputs to 2-phase, 4-wire bipolar stepper motors

Quadrature signals, (A, /A, B, /B, X, /X), differential (X, /X Index signals not required) 5 MHz maximum line frequency (20 M counts/sec) Digital Incremental Encoder

Encoder power +5 Vdc ±2% @ 400 mAdc max

Motemp [IN11] Motor overtemperature switch input. Active level programmable

Programmable to disable drive when motor over-temperature condition occurs

PROTECTIONS

Drive outputs turn off until $\,$ +HV < HV $_{\rm max}$ (See Input Power for HV $_{\rm max}$) HV Overvoltage $+HV > HV_{max}$

HV Undervoltage +HV < +14 Vdc Drive outputs turn off until +HV > +14 VdcHeat plate > 80°C. Drive over temperature Drive outputs turn off

Short circuits Output to output, output to ground, internal PWM bridge faults I²T Current limiting Programmable: continuous current, peak current, peak time Motor over temperature Digital inputs programmable to detect motor temperature switch

Inadequate analog encoder amplitude or missing incremental encoder signals Feedback Loss

MECHANICAL & ENVIRONMENTAL

Size mm [in] 76.3 x 58.2 x 20.5 [3.01 x 2.29 x 0.81] Weight 0.27 lb (0.12 kg) without heatsink

Ambient temperature -40 to +70°C operating, -50 to +85°C storage Humidity 0 to 95%, non-condensing, operating or storage

3.85 grms, 5~500 Hz (sine) Vibration Altitude

-400 to 12,200 m non-operating, -400 to 5,000 m operating Shock

75 g peak crash safety, 40 g peak operating Contaminants

Pollution degree 2 IEC68-2: 1990 Environment

Cooling Heat sink and/or forced air cooling required for continuous power output

AGENCY STANDARDS CONFORMANCE

In accordance with EC Directive 2014/30/EU (EMC Directive)

EN 55011: 2009/A1:2010 CISPR 11:2009/A1:2010

Industrial, Scientific, and Medical (ISM) Radio Frequency Equipment -

Electromagnetic Disturbance Characteristics - Limits and Methods of Measurement

Group 1, Class A

EN 61000-6-1: 2007 Electromagnetic Compatibility (EMC) - Part 6-1: Generic Standards -

Immunity for residential, Commercial and Light-industrial Environments

In accordance with EC Directive 2014/35/EU (Low Voltage Directive)

IEC 61010-1:2010 Safety Requirements for Electrical Equipment for Measurement, Control and Laboratory Use

Underwriters Laboratory Standards

UL 61010-1, 3rd Ed.: 2012 Electrical Equipment for Measurement, Control and Laboratory Use;

Part 1: General Requirements

UL File Number E249894

Copley Controls, 20 Dan Road, Canton, MA 02021, USA P/N 16-01591 Rev 00

Fax: 781-828-6547 Tel: 781-828-8090

Page 3 of 26





RoHS

COMMAND INPUTS

CANOPEN

Based on the CAN V2.0b physical layer, a robust, two-wire communication bus originally designed for automotive use where low-cost and noise-immunity are essential, CANopen adds support for motion-control devices and command synchronization. The result is a highly effective combination of data-rate and low cost for multi-axis motion control systems. Device synchronization enables multiple axes to coordinate moves as if they were driven from a single control card.


CANOPEN COMMUNICATION

R52 uses the CAN physical layer signals CANH, CANL, and GND for connection, and CANopen protocol for communication. Before installing the drive in a CAN system, it must be assigned a CAN Node-ID (address). A maximum of 127 CAN nodes are allowed on a single CAN bus. Up to seven digital inputs can be used to produce CAN Node-IDs from $1\sim127$, or the Node-IDs can be saved to flash memory in the module. Node-IDs 0 is reserved for the CANopen master on the network.

For more information on CANopen communications, download the CANopen Manual from the Copley web-site: CANopen Manual

DIGITAL COMMAND INPUTS

The graphic below shows connections between the R52 and a Dsub 9M connector on a CAN card. If the R52 is the last node on a CAN bus, the internal terminator resistor can be used by adding a connection on the PC board as shown. The Node-IDs of the R52 may be set by using digital inputs, or programmed into flash memory in the drive.




CME2 -> Basic Setup -> Operating Mode Options



RS-232 COMMUNICATIONS

R52 is configured via a three-wire, full-duplex DTE RS-232 port that operates from 9600 to 115,200 Baud, 8 bits, no parity, and one stop bit. Signal format is full-duplex, 3-wire, DTE using RxD, TxD, and Gnd. Connections to the *R52* RS-232 port are through P2 The graphic below shows the connections between an *R52* and a computer COM port which is a DTE device.



CME2 -> Tools -> Communications Wizard



Tel: 781-828-8090 Fax: 781-828-6547

Page 4 of 26



CU/CD





COMMAND INPUTS


DIGITAL POSITION

Digital position commands can be in three formats: Pulse & Direction, Count-Up/Count-Down (CU/CD), and quad A/B encoder. The active edge of the waveforms is programmable and the ratio of input pulses to motor microsteps is programmable, too. The Invert Command selection will reverse the direction of motion commanded by the inputs without changing the wiring.

PULSE & DIRECTION







CME2 -> Basic Setup -> Operating Mode Options




CME2 -> Basic Setup -> Operating Mode Options

QUAD A/B ENCODER

DIGITAL VELOCITY

Digital velocity commands are PWM signals in two formats: PWM 50% is a single signal that commands 0 at 50% duty cycle, with increasing or decreasing duty cycle to command positive or negative values. PWM & Direction format uses a PWM signal that goes from 0% to 100% to command magnitude while a 0/1 at the Dir input commands direction.


PWM 50%



CME2 -> PWM Command block



PWM & DIRECTION



CME2 -> PWM Command block



DIGITAL COMMAND FAIL-SAFE

In the position and velocity modes above, the 0% and 100% conditions can be programmed to command zero output. This is to protect against conditions that can occur with broken or disconnected cables which might produce uncontrolled motion.

Tel: 781-828-8090 Fax: 781-828-6547

Page 5 of 26







Fax: 781-828-6547

Page 6 of 26

SERVO MODE

Servo mode operates a stepper like a brushless servo motor taking position feedback from an encoder and controlling position, velocity, or torque. Command inputs include all of the digital inputs and modes as well as the $\pm 10V$ analog input which can control position, velocity, and current.

ANALOG COMMAND INPUT

In addition to the digital position and velocity inputs on the preceding page, the analog input can be used to control position, velocity, and torque.

CME2 -> Basic Setup -> Feedback Options

Motor Encoder: Primary Incremental

Differential Single Ended

Run in Servo Mode


CME2 -> Basic Setup -> Operating Mode Options

Operating Mode: Position

Command Source: Analog Command

CME2 -> Basic Setup -> Operating Mode Options

Command Source: Analog Command




Tel: 781-828-8090



INPUT-OUTPUT


HIGH SPEED DIGITAL INPUTS VIN TOLERANCE SEE CHART



<u>Ro</u>HS INPUT VIN P2 PIN R1 R2 C1 IN1 15 IN2 18 IN₃ 17 IN4 20 IN₅ 19 100P 10K IN₆ 22 21 IN7 IN8 24 IN9 23 IN10 47P 26 IN11 4.99K 25 10K 33N IN12 11 24 IN13 13 15K 100P 15K IN14 12

DIGITAL OUTPUTS

VOUT MAX (SEE CHART)



OUTPUT	P2 PIN	VOUT
OUT1	31	30
OUT2	32	30
OUT3	29	
OUT4	30	5
OUT5	27	5
OUT6	28	

DIODES SHOWN ON OUTPUTS MUST BE SUPPLIED WHEN DRIVING INDUCTIVE LOADS.

CANOPEN NODE-ID (ADDRESS) SWITCHES

The SLI (Switch & LED Interface) port takes in the 8 signals from the two BCD encoded switches that set the CANopen Node-IDs and controls the LEDs on the CANopen port connectors.

5V MAX

The graphic below shows the circuit for reading the CANopen Node-ID switches.


The 74HC165 works as a parallel-in/serial-out device.

The 10k pull-down resistors pull the shift register inputs to ground when the R52 is initializing.

In the graphics below, switch SW13 is "S2" and SW12 is "S1". The values of S1 are 16~255 and of S2 are 0~15.


Together they provide Node-ID range of 0~255.

CME2 -> Amplifier -> Network Configuration



CME2 -> Input/Output -> Digital Outputs





Tel: 781-828-8090

Fax: 781-828-6547

Page 7 of 26







MOTOR CONNECTIONS


Motor connections consist of: phases, encoder, thermal sensor, and brake. The phase connections carry the drive output currents that drive the motor to produce motion. The Hall signals are three digital signals that give absolute position feedback within an electrical commutation cycle. The encoder signals give incremental position feedback and are used for velocity and position modes, as well as sinusoidal commutation. A thermal sensor that indicates motor overtemperature is used to shut down the drive to protect the motor. A brake can provide a fail-safe way to prevent movement of the motor when the drive is shut-down or disabled.

QUAD A/B INCREMENTAL ENCODER


Encoders with differential line-driver outputs provide incremental position feedback via the A/B signals and the optional index signal (X) gives a once per revolution position mark.

DIGITAL QUADRATURE ENCODER INPUT 5V

* 121Ω terminating resistors on mounting board



CME2 -> Motor/Feedback -> Feedback



Copley Controls, 20 Dan Road, Canton, MA 02021, USA P/N 16-01591 Rev 00

Tel: 781-828-8090 Fax: 781-828-6547

Page 8 of 26






MOTOR CONNECTIONS (CONT'D)


SECONDARY QUAD A/B/X INCREMENTAL ENCODER

Digital inputs [IN4,5,6] can be programmed as secondary encoder inputs. The graphic shows a differential line receiver on the user mounting board to convert typical encoder signals into single-ended ones for the secondary inputs. Single-ended encoders would connect directly to the inputs of the R52.

CME2 -> Basic Setup -> Feedback Options



The CME2 screen above shows a Primary Incremental encoder for the motor input. Other types of encoders can be selected for this function. The secondary encoder input can be used for either motor or position feedback.






RoHS

MOTOR CONNECTIONS (CONT'D)

PHASE CONNECTIONS

The drive output is a three-phase PWM inverter that converts the DC bus voltage (+HV) into three sinusoidal voltage waveforms that drive the motor phase-coils. Cable should be sized for the continuous current rating of the drive. Motor cabling should use twisted, shielded conductors for CE compliance, and to minimize PWM noise coupling into other circuits. The motor cable shield should connect to motor frame and the drive HV ground terminal (J2-1) for best results. When driving a DC motor, the W output is unused and the motor connects between the U & V outputs.






MOTOR OVER TEMP INPUT


The 4.99k pull-up resistor works with PTC (positive temperature coefficient) thermistors that conform to BS 4999:Part 111:1987 (table below), or switches that open/close indicating a motor over-temperature condition. The active level is programmable.

PROPERTY	OHMS
RESISTANCE IN THE TEMPERATURE RANGE 20°C TO +70°C	60~750
RESISTANCE AT 85°C	≤1650
RESISTANCE AT 95°C	≥3990
RESISTANCE AT 105°C	≥12000



Tel: 781-828-8090

CME2 -> Input / Output








RoHS

CONNECTIONS FOR INCREMENTAL DIGITAL ENCODER



NOTES:

- 1. P3 connections use multiple pins to share current.

 All signals of the same name must be connected on the PC board to which the R52 is mounted.
- 2. The CANopen connector is shown to illustrate connections between the R52 and external cabling. The connector is not part of the R52 and non-signal connections are not shown.



RoHS

PRINTED CIRCUIT BOARD CONNECTORS & SIGNALS


P1 POWER & MOTOR

PI POWER & MOTOR			
SIGNAL	PIN		SIGNAL
+HV	2	1	
+HV	4	3	+HV
+HV	6	5	+HV
HVGND	8	7	HVGND
HVGND	10	9	HVGND
HVGND	12	11	HVAUX
	14	13	
MOT A	16	15	MOT A
MOT A	18	17	MOT A
	20	19	
	22	21	
MOT /A	24	23	MOT /A
MOT /A	26	25	MOT /A
	28	27	
	30	29	
MOT B	32	31	MOT B
МОТ В	34	33	мот в
	36	35	
	38	37	
MOT /B	40	39	MOT /B
MOT /B	42	41	MOT /B

P1: Power & Motor Dual row, 2 mm- centers 42 position female header SAMTEC SQW-121-01-L-D

TOP VIEW

Viewed from above looking down on the connectors or PC board footprint to which the module is mounted



P3 CANOPEN

SIGNAL	PIN		SIGNAL
CAN_GND	2	1	CAN_GND
CAN_GND	4	3	CAN_GND
CAN_GND	6	5	CAN_GND
CAN_TERM	8	7	CAN_L
CAN_GND	10	9	CAN_H
CAN_GND	12	11	CAN_GND
CAN_GND	14	13	CAN_GND
CAN_GND	16	15	CAN_GND

P3: CANopen Dual row, 2 mm- centers 16 position female header SAMTEC SQW-108-01-L-D

P2 CONTROL

Tel: 781-828-8090

SIGNAL	P)		SIGNAL
RS-232 TXD	2	1	RS-232 RXD
ENC S	4	3	ENC /S
ENC A	6	5	ENC /A
ENC B	8	7	ENC /B
ENC X	10	9	ENC /X
HALL W	12	11	HALL U
ENC +5V	14	13	HALL V
SGND	16	15	[IN1] ENABLE
[IN2]	18	17	[IN3]
[IN4]	20	19	[IN5]
[IN6]	22	21	[IN7]
[IN8]	24	23	[IN9]
MISO [IN10]	26	25	[IN11] MOTEMP
SS2 [OUT6]	28	27	[OUT5] SS1
SCLK [OUT4]	30	29	[OUT3] MOSI
[OUT2]	32	31	[OUT1]
SGND	34	33	SGND
REF (-)	36	35	REF (+)
N.C.	38	37	N.C.
N.C.	40	39	N.C.

P2: Control

Dual row, 2 mm- centers 40 position female header SAMTEC SQW-120-01-L-D

NOTES:

- 1. P1 connections use multiple pins to share current. *All signals of the same name must be connected* on the PC board to which the R52 is mounted.
- Cells in table above that are filled in grey are connector contacts that have no circuit connections.






RoHS

PRINTED CIRCUIT BOARD FOOTPRINT

DIMENSIONS ARE IN[MM]

TOP VIEW

Viewed from above looking down on the connectors or PC board footprint to which the module is mounted



PCB Hardware:

Qty	Description	Mfgr	Part Number	Remarks
1	Socket Strip	Samtec	SQW-121-01-L-D	J1 HV & Motor
1	Socket Strip	Samtec	SQW-120-01-L-D	J2 Control
1	Socket Strip	Samtec	SQW-108-01-L-D	J3 CANopen
2	Standoff	PEM	KFE-4/40-8ET	#4/40 X 1/4"

Additional Hardware (not shown above)

2 Screw, #4-40 x 1.25" Phillips Pan Head External Tooth Lockwasher SEMS, Stainless, or steel with nickel plating, Torque to $3\sim5$ lb-in $(0.34\sim0.57~N\cdot m)$

Notes

- $1.\ J1$ signals of the same name must be connected for current-sharing (see graphic above).
- To determine copper width and thickness for J3 signals refer to specification IPC-2221. (Association Connecting Electronic Industries, http://www.ipc.org)
- 3. Standoffs or mounting screws should connect to etch on pc board that connect to frame ground for maximum noise suppression and immunity.

Copley Controls, 20 Dan Road, Canton, MA 02021, USA P/N 16-01591 Rev 00


Tel: 781-828-8090 Fax: 781-828-6547 Page 13 of 26








DIMENSIONS

DIMENSIONS ARE MM [IN]











DEVELOPMENT KIT



DESCRIPTION


The Development Kit provides mounting and connectivity for one R52 drive. Solderless jumpers ease configuration of inputs and outputs to support their programmable functions. Switches can be jumpered to connect to digital inputs $1{\sim}11$ so that these can be toggled to simulate equipment operation. Six LED's provide status indication for the digital outputs. Dual CANopen connectors make daisy-chain connections possible so that other CANopen devices such as Copley's Stepnet Plus or Xenus Plus CANopen drives can easily be connected.



RS-232 CONNECTION


The RS-232 port is used to configure the drive for stand-alone applications, or for configuration before it is installed into an CANopen network. CME 2^{TM} software communicates with the drive over this link and is then used for complete drive setup. The CANopen Slave Node-ID that is set by the rotary switch can be monitored, and a Node-ID offset programmed as well.

The RS-232 connector, J9, is a modular RJ-11 type that uses a 6-position plug, four wires of which are used for RS-232. A connector kit is available (SER-CK) that includes the modular cable, and an adaptor to interface this cable with a 9-pin RS-232 port on a computer.



SER-CK SERIAL CABLE KIT

The SER-CK provides connectivity between a D-Sub 9 male connector and the RJ-11 connector J9 on the Development Kit. It includes an adapter that plugs into the COM1 (or other) port of a PC and uses common modular cable to connect to the XEL. The connections are shown in the diagram below.





Tel: 781-828-8090

Don't forget to order a Serial Cable Kit SER-CK when placing your order for an R52 Development Kit!




RoHS

CANOPEN CONNECTORS

Dual RJ-45 connectors that accept standard Ethernet cables are provided for CAN bus connectivity. Pins are wired-through so that drives can be daisy-chained and controlled with a single connection to the user's CAN interface. A CAN terminator should be placed in the last drive in the chain. The R52-NK connector kit provides a D-Sub adapter that plugs into a CAN controller and has an RJ-45 socket that accepts the Ethernet cable.

SPK-NK CAN CONNECTOR KIT

The kit contains the SPK-CV adapter that converts the CAN interface D-Sub 9M connector to an RJ-45 Ethernet cable socket, plus a 10 ft (3 m) cable and terminator. Both connector pin-outs conform to the CiA DR-303-1 specification.



INDICATORS (LEDS)

The AMP LED on J9 shows the operational state of the R52. The STATUS LED on J9 shows the state of the CANopen NMT (Network Management) state-machine in the drive. LEDs on J10 show activity on the CANopen network. Details on the NMT state-machine can be found in the CANopen Programmers Manual, §3.1: http://www.copleycontrols.com/Motion/pdf/CANopenProgrammersManual.pdf

AMP LED

A single bi-color LED gives the state of the R52 by changing color, and either blinking or remaining solid. The possible color and blink combinations are:

• Green/Solid: Drive OK and enabled. Will run in response to reference inputs or CANopen commands.

• Green/Slow-Blinking: Drive OK but NOT-enabled. Will change to Green/Solid when enabled.

• Green/Fast-Blinking: Positive or Negative limit switch active. Drive will only move in direction not inhibited by limit switch.

• Red/Solid: Transient fault condition. Drive will resume operation when fault is removed.

• Red/Blinking: Latching fault. Operation will not resume until drive is Reset.

Drive Fault conditions. Faults are programmable to be either transient or latching:

Over or under-voltage

• Motor over-temperature

• Encoder +5 Vdc fault

· Short-circuits from output to ground

Drive over-temperature


Tel: 781-828-8090

- · Internal short circuits
- Short-circuits from output to output

J9 RS-32 SERIAL



J10 CAN CONNECTIONS



STATUS LED

A single bi-color LED gives the state of the NMT state-machine by changing color, and either blinking or remaining solid. The possible color and blink combinations are:

RUN (GREEN)

• Off Init

Blinking Pre-operational
 Single-flash Stopped
 On Operational

ERROR (RED)

• Off No error

• Blinking Invalid configuration, general configuration error

• Single Flash Warning limit reached

Double Flash
 Triple Flash
 Error Control Event (guard or heartbeat event) has occurred
 Sync message not received within the configured period

• On Bus Off, the CAN master is bus off

ACT LED

Flashing indicates the R52 is sending/receiving data via the CAN port

Note: Red & green led ontimes do not overlap. LED color may be red, green, off, or flashing of either color.

Copley Controls, 20 Dan Road, Canton, MA 02021, USA P/N 16-01591 Rev 00

Fax: 781-828-6547

Page 16 of 26



RUGGEDIZED DIGITAL STEPPER DRIVE MODULE

RoHS


DEVELOPMENT KIT

CANOPEN NODE-ID (ADDRESS) SWITCH CONNECTIONS

The graphic below shows the connections to the CANopen Node-ID switches. These are read after the drive is reset, or powered-on. When changing the settings of the switches, be sure to either reset the drive, or to power it off-on. Outputs [OUT3,4,5] and input [IN10] operate as an SLI (Switch & LED Interface) port which reads the settings on the CANopen Node-ID switches, and controls the LEDs on the serial and CANopen port connectors.

The jumpers marked with red "X" should be removed so that SW10, or external connections to the signals do not interfere with the operation of the SLI port.

CME2 -> Input/Output -> Digital Outputs



5V POWER SOURCES

The feedback connector J7 has connections for two power supplies:


Pin 6 has +5V supplied by the R52 module

Pin 17 connects to jumper J4 for the selection of the 5V power source:

On J4, when the jumper connects pins 2 & 3, the power source is the R52 internal supply (the default setting) When the jumper is on pins 1 & 2, the power source comes from an external power supply connecting to J5-1.

5V power on the Development Kit that comes from the selectable 5V power source on J4 is labeled "5V SEL".

Circuits powered by 5V supplied only by the R52 are labeled "5V R52"



Copley Controls, 20 Dan Road, Canton, MA 02021, USA P/N 16-01591 Rev 00

Tel: 781-828-8090 Fax: 781-828-6547


Page 17 of 26



LOGIC INPUTS & SWITCHES


The Development Kit has jumpers that can connect the R52 digital inputs to switches on the kit, or to the Signal connector J8. As delivered, all of these jumpers are installed as shown. If connecting to external devices that actively control the level of an input, it is desirable to disconnect the switch which could short the input to ground.

For example, if [IN1] is connected to an external device for the Enable function, then jumper JP2A should be removed to take the switch SW1 out of the circuit. The figure below shows these connections.



LOGIC OUTPUTS

There are six logic outputs that can drive controller logic inputs or relays. If relays are driven, then flyback diodes must be connected across their terminals to clamp overvoltages that occur when the inductance of the relay coil is suddenly turned off. Outputs 3,4,5 & 6 are CMOS types that pull up to 5V or down to ground. When these outputs go high it turns on the green LED. When they are low, the red LED is turned on. Outputs 1 & 2 are MOSFET types that sink current when ON, and appear as open-circuit when OFF. When these outputs are ON a red LED is turned on. When the outputs are OFF, the red LED is off. The green LED is not used on these outputs.





MOTOR FEEDBACK CONNECTOR J7

For motors with differential encoders: install jumpers JP1B, JP1D, JP1F, and JP1H to connect 121 ohm terminators across inputs Jumpers JP1A, JP1C, JP1E, and JP1G do not affect this setting and may remain in place or be removed.


For motors with single-ended encoders: remove jumpers JP1B, JP1D, JP1F, and JP1H to disconnect 121 ohm terminators Install jumpers JP1A, JP1C, JP1E, and JP1G

A motor temperature sensor that connects to [IN11] must have jumper JP4F installed and JP3C removed to prevent switch SW11 from grounding the Motemp[IN11] signal.

If the encoder has a fault output, then jumper JP4H must be in place and jumper JP3A must be removed to prevent switch SW9 from grounding the Enc Fault [IN9] signal.

Absolute encoders such as the Nikon A type that use 2-wire bidirectional signals require biasing the lines when they are in a quiescent state. Jumpers JP1G, JP1H, and JP6A must be in place to provide line termination and biasing.

LED's are provided to show the status of the encoder and Hall signals.




Tel: 781-828-8090



DEVELOPMENT KIT



DEVELOPMENT KIT CONNECTIONS



Notes:


1. CANopen connectors J10 are not shown here. For details see pp 4 & 13.



DEVELOPMENT KIT

The Development Kit mounts a single R52 module and enables the user to test and operate the R52 before it is mounted onto a PC board in the target system.

J6 AUX HV & EXT 5V



J7 FEEDBACK

PIN	SIGNAL	PIN	SIGNAL	PIN	SIGNAL
26	Sgnd	18	N.C.	9	Enc X1
25	Sgnd	17	+5 Vdc Out	8	Enc /X1
24	Enc Fault	16	Sgnd	7	[IN11] Motemp
23	N.C.	15	Enc S1	6	+5 Vdc Out
22	N.C.	14	Enc /S1	5	Sgnd
21	N.C.	13	Enc A1	4	[IN14]
20	N.C.	12	Enc /A1	3	[IN13]
19	N.C.	11	Enc B1	2	[IN12]
		10	Enc /B1	1	Frame Gnd

Fax: 781-828-6547 Tel: 781-828-8090

Page 21 of 26




J11 CAN NETWORK TERMINATOR

		1
PINS	FUNCTION	1 2 3
		1 2 0
1-2	TERMINATOR	
	ON	
2-3	TERMINATOR	
	UFF	I

J10 CANOPEN

PIN	SIGNAL
8	(CAN_V+) 1
7	CAN_GND
6	(CAN_SHLD) 1
5	Reserved
4	No Connection
3	CAN_GND
2	CAN_L
1	CAN_H

NODE-ID (ADDRESS) SWITCHES



J9 RS-232

SIGNAL
N.C.
TXD
SGND
SGND
RXD
N.C.

J8 CONTROL

PIN	SIGNAL	PIN	SIGNAL		
9	N.C.	18	[OUT3] MOSI	PIN	SIGNAL
8	[IN5] HS	17	[OUT2] GP	26	[IN7] HS
7	[IN4] HS	16	[OUT1] GP	25	[IN8] HS
6	[IN3] HS	15	Sgnd	24	[IN10] MISO
5	[IN2] HS	14	N.C.	23	[OUT4] CLK
4	[IN1] HS	13	N.C.	22	[OUT5] EN1
3	[AIN1-]	12	N.C.	21	[OUT6] EN2
2	[AIN1+]	11	N.C.	20	+5 Vdc Out
1	Frame Gnd	10	[IN6] HS	19	Sgnd






RoHS

POWER DISSIPATION

The charts on this page show the drive's internal power dissipation for different models under differing power supply and output current conditions. Drive output current is calculated from the motion profile, motor, and load conditions. The values on the chart represent the rms (root-mean-square) current that the drive would provide during operation. The +HV values are for the average DC voltage of the drive power supply.

To see if a heatsink is required or not, the next step is to determine the temperature rise the drive will experience when it's installed. For example, if the ambient temperature in the drive enclosure is 45 °C, and the heatplate temperature is to be limited to 80° C or less to avoid shutdown, the maximum rise would be 80C - 45C. or 35° C. Dividing this dissipation by the thermal resistance of 9° C/W with no heatsink gives a dissipation of 3.9W. This line is shown in the chart. For power dissipation below this line, no heatsink is required. The vertical dashed lines show the continuous current ratings for the drive models.




HEATSINK INSTALLATION USING THE R52-HK HEATSINK KIT

An AOS Micro Faze thermal pad is used in place of thermal grease. This material comes in sheet form and changes from solid to liquid form as the drive warms up. This forms an excellent thermal path from drive heatplate to heatsink for optimum heat transfer.

STEPS TO INSTALL

- Remove the thermal pad from the clear plastic carrier.
- Place the thermal pad on the Stepnet aluminum heatplate taking care to center the thermal pad holes over the holes in the drive body.
- Mount the heatsink onto the thermal pad again taking care to see that the holes in the heatsink, thermal pad, and drive all line up.
- 4. Torque the #4-40 mounting screws to $3\sim5$ lb-in $(0.34\sim0.57\ N\cdot m)$.





RoHS

HEATSINK OPTIONS


Rth expresses the rise in temperature of the drive per Watt of internal power loss. The units of Rth are $^{\circ}$ C/W, where the $^{\circ}$ C represent the rise above ambient in degrees Celsius. The data below show thermal resistances under convection, or fan-cooled conditions for the no-heatsink, and R52-HS heatsink.

NO HEATSINK



NO HEATSINK	C/W
CONVECTION	9.1
FORCED AIR (300 LFM)	3.3

STANDARD HEATSINK (R52-HK)



WITH HEATSINK	C/W
CONVECTION	5.3
FORCED AIR (300 LFM)	1.1

Tel: 781-828-8090





RoHS 9

Fax: 781-828-6547

Page 25 of 26

Tel: 781-828-8090

THIS PAGE LEFT BLANK INTENTIONALLY











İ	R52-090-07	Stepnet R52 stepper drive, 5/7 A, 20~90 Vdc
<u> </u>		Stepnet R52 stepper drive, 10/10 A, 20~90 Vdc
		Development Kit for R52 stepper drive

CANOPOR

ACCESSORIES

	QTY	DESCRIPTION	
	1	Connector, Euro, 5 Terminal, 5.08 mm	
Connector Kit	1	Connector, Euro, 4 Terminal, 5.08 mm	
for Develop- ment Kit	1	26 Pin Connector, High Density, D-Sub, Male, Solder Cup	
SPK-CK-01	2	26 Pin Connector, High Density, D-Sub, Female, Solder Cup	
	1	26 Pin Connector Backshell	
CANopen	1	Adapter Assy, DB9 Female to RJ45 Jack (SPK-CV)	
Network Kit	1	CANopen Network Cable, 10 ft. (SPK-NC-10)	
SPK-NK	1	CANopen Network Terminator (SPK-NT)	
	1	Heatsink for R52	
Heatsink Kit R52-HK	1	Heatsink Thermal Pad	
	2	Screws, #4/40 x 1.25", SEMS	
SPK-CV SPK-NC-10		Adapter Assembly, DB9 Female to RJ45 Jack	
		CANopen Network Cable, 10 ft	
SPK-NC-10		CANopen network cable, 1 ft	
SPK-NC-10		CANopen Network Terminator	
CME 2		CME 2 Drive Configuration Software on CD-ROM	
SER-CK		Serial Cable Kit for Development Kit	

16-01591 Document Revision History

Revision	Date	Remarks	
00	March 9, 2017	Initial released version	

Note: Specifications subject to change without notice

Fax: 781-828-6547 Page 26 of 26

Tel: 781-828-8090